

**Table at007**  
**Significant Industrial Users - Summary of Enforcement Case Activities**  
**City of Los Angeles Pretreatment Program**  
1/1/2020 to 12/31/2020

<b>Case Number:</b> E121194		IU Number: IU011597	Permit Number: 492943 433	District: 02 Subdistrict: 04
<u>ACCURATE ENGINEERING, INC.</u>		DBA	<u>ACCURATE ENGINEERING, INC.</u>	
Status: <b>TE</b>	Location Address 8710 TELFAIR Avenue SUN VALLEY, CA 91352		Case Termination Date: 3/2/2020	
Case Start Date: 05/29/2019		Case Compliance Due Date: 1/31/2020		
<u>Violation History:</u>	Cu (T) federal daily & monthly and local limits.			
06/03/2019	POTW	Issued Cease & Desist Order		
09/04/2019	POTW	Issued Draft Compliance Order		
09/16/2019	POTW	Conducted Compliance Meeting		
09/20/2019	POTW	Issued Compliance Order		
01/31/2020	IU	Final Compliance Due Date		
03/02/2020	POTW	Terminated Enforcement Action		
<u>Corrective Actions:</u>	IU installed a new higher capacity pretreatment system consisting of equalization tank, treatment tank, lamella clarifier, filter press and automated chemical injection system. IU also added a manually operated batch treatment system.			
<u>Pollution Prevention:</u>	IU implemented water conservation measures by making operational and process changes.			

**Table at007**  
**Significant Industrial Users - Summary of Enforcement Case Activities**  
**City of Los Angeles Pretreatment Program**  
1/1/2020 to 12/31/2020

<b>Case Number:</b>	<b>E121503</b>	IU Number:	IU105110	Permit Number:	511717 439	District:	01	Subdistrict:	01
<u>Levlad, LLC</u>				DBA				<u>Levlad, LLC</u>	
Status:	TE			Location Address		Case Termination Date:	5/19/2020		
				9200 Mason Avenue					
				Chatsworth, CA 91311					
Case Start Date:	07/26/2019					Case Compliance Due Date:	12/10/2019		
<u>Violation History:</u>		O&G (T) local limit.							
08/07/2019	POTW			Issued Draft Compliance Order					
08/22/2019	POTW			Conducted Compliance Meeting					
09/05/2019	POTW			Issued Compliance Order					
12/10/2019	IU			Final Compliance Due Date					
05/19/2020	POTW			Terminated Enforcement Action					
<u>Corrective Actions:</u>		IU modified the pretreatment system to enhance the removal of O & G.							
<u>Pollution Prevention:</u>		IU made operational changes to reduce emulsification of O & G in the wastewater.							